

TOSHIBA	Toshiba Transmission & Distribution Systems (India) Pvt.Ltd. Distribution Transformers Division	Engineering
		Unit-10

**GUARANTEED TECHNICAL PARTICULARS
THREE PHASE DISTRIBUTION TRANSFORMER**

Enquiry No : 10223-4	Customer : KKM POWER , FINLAND				
kVA : 315	kV :11/0.42	Phase : 3	Freq. : 50Hz	Cooling : ONAN	Doc No: EGT 40748R1

Sl. No.	Description	UNIT	315 kVA
1)	Make		Toshiba Transmission & Distribution Systems (India) Pvt. Ltd
2)	Type		Hermitically Sealed
3)	Phases	No.	Three
4)	Rating	kVA	315 kVA
5)a)	Rated Voltage:		
	HV	V	11000
	LV	V	420
b)	Highest voltage for equipment		
	HV	kV	12
	LV	kV	1
6)	Tappings		+5.0% to -5.0 % in steps of 2.5%
7)	Frequency	Hz	50
8)	Vector Group		Dyn11
9)	Insulation Level		
	HV	kV peak	75
	LV	kV peak	Not Applicable
10)	Power Frequency Level		
	HV	kV rms	28
	LV	kV rms	3
11)	Winding material		Aluminum
12)	Core Material		CRGO
13)	Temperature Rise:		
	Oil	°C	60
	Winding	°C	65
14)	Losses		
	No Load Losses at rated Voltage and Frequency	Watt	360 (MAX)-A0
	Load Losses at 75 °C	Watt	3900 (MAX)-Ck
15)	Impedance Voltage	%	4% (+/- IEC Tolerance Applicable)

TOSHIBA		Toshiba Transmission & Distribution Systems (India) Pvt.Ltd. Distribution Transformers Division		Engineering
				Unit-10
16)	Percentage Resistance	%	1.24	
17)	Regulation at:			
	Full Load UPF	%	1.31	
	Full Load 0.8 PF	%	3.30	
18)	Efficiency at 0.8 PF:			
	Full Load	%	98.34	
	¾ Full Load	%	98.67	
	½ Full Load	%	98.95	
19)	Terminal Arrangement:			
	HV			Bare Bushings – Porcelain-12kV/250A
	LV			Bare Bushings – Porcelain-1kV/630A
20)	Actual Overall Dimensions:			
	Length	mm		As per OGA drawing
	Width	mm		As per OGA drawing
	Height	mm		As per OGA drawing (without rollers)*
21)	Overall Weight			
	Total Weight	Kg.	1260	
22)	Noise Level	LwA dB(A)	49	
Applicability of Optional Fittings For above mentioned Actual Overall Dimensions				
23)	Rollers			Yes
24)	Pole Mounting consoles			No
25)	HV flags/connector/lug			No
26)	LV flags/connector/lug			No
27)	HV Tapping/Tap Switch			Yes

Note:

1. Actual overall dimensions and weights are subjected to +/-10% Tolerance, provided that the tolerance is not exceeded the maximum value defined.
2. All the efficiencies and regulations are calculated at the nominal values of NLL, LL AT 75 Deg C and % Z at 75 Deg C.
3. * With Rollers transformer height will increase by 100mm.
4. With HV flags transformer overall height will increase.